

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Emergency stop switch

Name and address of the applicant

EMAS ELEKTROTEKNİK MAKİNA SANAYİ VE TİCARET A.Ş.
Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı
Mehmet Hilmi Caddesi No.12
34555 Arnavutköy- İstanbul
Türkiye

Name and address of the manufacturer

EMAS ELEKTROTEKNİK MAKİNA SANAYİ VE TİCARET A.Ş.
Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı
Mehmet Hilmi Caddesi No.12
34555 Arnavutköy- İstanbul
Türkiye

Name and address of the factory

Note: When more than one factory, please report on page 2

EMAS ELEKTROTEKNİK MAKİNA SANAYİ VE TİCARET A.Ş.
Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı
Mehmet Hilmi Caddesi No.12
34555 Arnavutköy- İstanbul
Türkiye

Ratings and principal characteristics

Ui=300V(B/H/CP/CM series), 250V(MB series);
Uimp=2,5kV; Ith=10A; Pollution degree: 3;
AC-15: 250VAC/4A(B/H series), 230VAC/4A(CP/CM series),
240VAC/3A(MB series), 50Hz; Direct opening action;
Rated conditional short-circuit current: 1kA

Trademark / Brand (if any)

emas

Customer's Testing Facility (CTF) Stage used

CTF Stage 1

Model / Type Ref.

abcde
(a=B, CM, CP, H, MB; b=0, 1, 2, 3, 4; c=0,1; d=0, 1, 2, 3,
4; e=E, E30, E60, EE, EG, EA30, EC, EP, ECN30, ECS30, ES30,
EK30, EEG, EEK)

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016
IEC 60947-5-5:1997+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

HU24A0G8 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com



Date: 2024-11-12

Signature: Wencai Zhang