

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Name and address of the applicant

Name and address of the manufacturer

Note: When more than one factory, please report on page 2

Product

Water Level Operating Control

EMAS ELEKTROTEKNÍK MAKÍNA SANAYÍ VE TÍCARET A.Ş.

Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı

Mehmet Hilmi Caddesi No.12 34555 Arnavutköy- İstanbul

Türkiye

EMAS ELEKTROTEKNİK MAKİNA SANAYİ VE TİCARET A.Ş.

Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı

Mehmet Hilmi Caddesi No.12 34555 Arnavutköy- İstanbul

Türkiye

EMAS ELEKTROTEKNİK MAKİNA SANAYİ VE TİCARET A.Ş.

Özar Özel Endüstri Bölgesi Deliklikaya Mahallesi Yüzbaşı

Mehmet Hilmi Caddesi No.12 34555 Arnavutköy- İstanbul

Türkiye

Ratings and principal characteristics

Name and address of the factory

250 V AC , 10(4) A , 50/60 Hz , T80 , IP68 (30m,2h)

Trademark / Brand (if any)

emas

Customer's Testing Facility (CTF) Stage used

CTF Stage 1

Model / Type Ref.

SKF xyz, SKF1A xyz, SKF1E xyz, SKF2 xyz For suffixes see Page 2 of this CB Test Certificate.

Additional information (if necessary may also be reported on page 2)

See additional page(s) for further Additional information.

A sample of the product was tested and found to be in conformity with

IEC 60730-2-15:2017 IEC 60730-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

HU240R8J 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division H-1143 Budapest, Gizella út 51-57., Hungary Web: www.tuv.com

Date: 2024-04-30 Signature: Szabó Péte



HU-004918

Page 2 of 2

Additional information :

```
Type designation:
SKF xyz; SKF1A xyz; SKF1E xyz; SKF2 xyz
where:
    x: Cable Length: 0,5 - 30 m
    y: Cable Type: H05VV-F, H05RR-F (3X1mm²)
    z: Weight Type: Cylinder Shaped, Diamond Shaped
```



Date: 2024-04-30

Signature:

